

**Rock Probe results:**  
 RP7 - no refusal to 15'  
 RP8 - no refusal to 10'  
 RP11 - no refusal to 10'



**Borehole observed water levels/cave-in:**  
 BH1 - WL = 5' and cave in = 5'6"  
 BH2 - cave in = 5'  
 BH3 - cave in = 2'6"  
 BH4 - WL = 3' and cave in = 8'6"  
 BH5 - WL = 1'6" and cave in = 3'  
 BH6 - WL = 2'4"  
 BH7 - not observed (shallow refusal)  
 BH8 - WL = 3' and cave in = 4'  
 BH9 - WL = 2' and cave in = 5'

Two additional rock probes, spaced 200 m and 400 m away from this borehole to the south on the gravel shoulder of Parry Sound Drive (See Drawing No. 2)

**Borehole results:**

- BH1 - earth/rock fill overlying **peat to 8'6"**, over compact sand and very stiff silty clay, refusal at 13'5"
- BH2 - earth/rock fill to about 7', compact sand below fill, refusal at 10'
- BH3 - pavement structure over earth/rock fill to about 5', overlying a sand deposit, refusal at 6'6" (moved 4'6" north, refusal at 7'4")
- BH4 - earth/rock fill to 5'6", **peat to 8'6"**, **very soft clay till 14'**, **loose sand to refusal at 19'6"**
- BH5 - earth/rock fill and **peat to 11'**, **very soft clay to 14'**, compact to very dense sand to 21' (refusal at 21')
- BH6 - earth/rock fill to refusal at 4' (relocate borehole 5'6" east, refusal at 2'6", relocate 5'9" east, refusal 2'8")
- BH7 - earth/rock fill to refusal at 3'7" (relocate 4' south, refusal at 3'1", relocate 8'9" south, refusal at 4', relocate 12'9" south, refusal 3'6")
- BH8 - earth **fill to 7'**, **peat to 10'**, **very soft clay to 15'6"** over sand, refusal at 16'3"
- BH9 - earth/rock fill to 3'6", **peat to 10'**, **very soft silty clay to 14'**, compact sand to refusal at 16'.

**LEGEND**

-  - Proposed Borehole Locations
-  - Proposed Rock Probe Locations

**Soil Engineers Ltd.**  
 CONSULTING ENGINEERS  
 GEOTECHNICAL | ENVIRONMENTAL | HYDROGEOLOGICAL | BUILDING SCIENCE  
 90 WEST BEAVER CREEK ROAD, SUITE #100, RICHMOND HILL, ONTARIO L4B 1E7 · TEL: (416) 754-8515 · FAX: (905) 881-8335

**BOREHOLE LOCATION PLAN**

SITE: 36 Smith Crescent, Town of Parry Sound			
DESIGNED BY: -	CHECKED BY: -	DWG NO.: 1	
SCALE: 1:1000	REF. NO.: 2004-S009	DATE: April 2020	REV 2